

Compliance Assistance Program

Stack Cap Requirements

To reduce air pollution, Northwest Clean Air Agency (NWCAA) has exhaust stack requirements depending on the type of operation and equipment used.

Surface coating operations (e.g. paint booths, etc.): Emissions are required to exhaust through unobstructed, vertical stacks above the eve of the roof. Permits may specify minimum stack heights. If a stack cap (sometimes called a rain guard) is installed, there are specific designs that meet air quality requirements (see below).


Other operations (e.g. baghouse, boiler, coffee roaster, cyclone, emergency generator set, etc.): NWCAA Agency recommends that emissions exhaust through unobstructed vertical stacks. Some permits require it. Be sure to check with your local city/county building department for applicable requirements.

Approved Stack Caps — Below are examples of stack cap designs that have been approved by NWCAA. Other designs may be submitted to NWCAA for approval prior to construction and installation.

1. Hexagonal Stack Cap

This design diverts air around an internal wedge used to catch rain. A hose is connected to the bottom of the wedge which drains the collected rain water.





2. Stack-in-a-Stack Cap

This design is based on the principle that rain falls at an angle. The inner stack is surrounded by an outer stack with space between the two. Rain runs down the inside wall of the outer stack, instead of down the inside wall of the inner stack and into the equipment being vented.





3. Hinged Stack Cap

A hinged flapper damper opens to a 45 degree angle or greater when the equipment is running and closes when turned off. A booster fan may need to be installed to help push open the flaps.





4. Inverted Cone Stack Cap

Grating or brackets support the cone which is suspended above the stack opening. The cone helps prevent rain from entering the stack. The angle of the cone must be 45 degrees or greater.



Where Can I Get Stack Caps?

Some companies specializing in mechanical contracting or sheet metal ducting also make stack caps. These companies can be found in the phone book, under "Mechanical Contractors" and "Sheet Metal Work."

Some stack caps are part of a larger system, such as a furnace, that comes as one package that is "UL listed" as meeting building code requirements.

If the stack has a cap, it is very important to provide NWCAA with design drawings or photos of the cap at the beginning of the air quality permitting process to ensure correct air pollution modeling.

If the cap obstructs the flow of exhaust, you may need to:


- Change the cap to an approved design to allow for unobstructed flow of the exhaust.
- Limit hours of operation.

Stack Configurations


Instead of installing a stack cap to prevent rain or snow from entering the stack, another option is to install a stack that allows precipitation to drain from within the stack. There are two common configurations:

1. Offset Elbow Stack:

The stack is offset using an elbow. The base of the elbow is enlarged at the bottom to create an opening that allows it to function as a drain. Rain runs down the inside wall of the stack and drains from the opening at the base of the elbow.



2. Offset Stack



About Us

Northwest Clean Air administers state, federal and local regulations for managing air quality in cities, towns and unincorporated areas of Island, Skagit and Whatcom Counties. NWCAA staff inspect air pollution sources, issue permits, monitor ambient air quality and educate the public about air quality.

Northwest Clean Air Agency was formed under the 1967 Clean Air Act of Washington (Chapter 70.A.15
RCW), which required larger counties within the State of Washington to activate local air pollution control authorities. There are seven local air agencies in the state, plus the Air Quality Program within the Washington State Department of Ecology.

For more information, call (360) 428-1617 or visit www.nwcleanairwa.gov.



1600 South Second Street Mount Vernon, WA 98273-5202